

VIGOROX® WWT II PROVIDED A MORE STABLE DISINFECTION PERFORMANCE FOR A WASTEWATER PLANT IN CALIFORNIA

CASE STUDY



PLANT BACKGROUND

- Name of Plant: City of St. Helena (California)
- Type of Wastewater and Upstream Treatment Processes: Municipal wastewater with aerated lagoon and an average flow rate of 0.5 million gallons per day
- Current Disinfection Process: sodium hypochlorite for chlorination and sodium bisulfite for dechlorination

CHALLENGES

- Performance of existing chlorination process becomes less effective during some periods of summer and fall months:
 - The pH of the lagoon effluent increased to 8.0 or higher during these months due to excessive algae growth.
 - This pH change shifts the chemical equilibrium of hypochlorite solution added from hypochlorous acid
 - (HOCl) to hypochlorite ions (OCl).
 - Since HOCl is much more effective as a disinfectant than OCl, much higher doses of sodium hypochlorite are required at higher pH. Plant operating data indicated that the required hypochlorite dose was 14 mg/L at pH of less than 8.0 and increased to 40 mg/L or higher when pH is 8.0 or higher.
 - The city sought a cost effective technology that could provide more stable disinfection performance over a broad range of pH conditions and could easily retrofit the existing system.

PROPOSED SOLUTION


- VIGOROX® WWT II is desirable because of its stable and high disinfection efficiency over a broad range of pH and of its capability of retrofitting into existing treatment train, in addition to its other unique features (e.g., ease of operation and very low toxicity to aquatic organisms).
- Provided complete services and process evaluation, including on site bench scale tests and full-scale trial.

RESULTS & CONCLUSIONS

- The three-month full-scale test confirmed the effectiveness of VIGOROX® WWT II and narrowed down the operating conditions needed to achieve the disinfection goal.
- Specifically, with Ct values (C being the dose in mg/L and t being contact time in minutes) of 400 mgmin/L of higher, VIGOROX® WWT II is able to comply with the permit limit (see Figure 1).

Figure 1

Full Scale Test Results: Total Coliform Count of VIGOROX® WWT II Treated Effluent at different Ct Values
(C: dose in mg/L, t: contact time in minutes)



Disclaimer

This information and all further technical advice are based on our present knowledge and experience. However, it implies no liability or other legal responsibility on our part, including with regard to existing third-party intellectual property rights, especially patent rights. In particular, no warranty, whether express or implied, or guarantee of product properties in the legal sense is intended or implied. We reserve the right to make any changes according to technological progress or further developments. The customer is not released from the obligation to conduct careful inspection and testing of incoming goods. Performance of the product described herein should be verified by testing, which should be carried out only by qualified experts in the sole responsibility of a customer. Reference to trade names used by other companies is neither a recommendation, nor does it imply that similar products could not be used.

PeroxyChem LLC

2005 Market Street,
Suite 3200,
Philadelphia, PA 19103
United States

+1 267 422 2400

www.active-oxygens.com